

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 16146a
Permit No. 212a
Basin 212a



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 17683

1. OWNER Maele WAMP
MAILING ADDRESS 1100 E. COLTON AVE
NORTH LAS VEGAS, NV

ADDRESS AT WELL LOCATION NLV, NV
1100 E. COLTON AVE

2. LOCATION NW 1/4 SE 1/4 Sec 11 T 20 N R 61 E CLARK County
MO-2282 Parcel No. 139-11-303-011 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other..... Municipal/Industrial Irrigation Test Cable Rotary RVC
 Stock Air Other Auger

6. LITHOLOGIC LOG

| Material | Water Strain | From | To | Thick-ness |
|--|--------------|----------|-----------|------------|
| <u>SILT SAND + SANDY CLAY INTERBEDDED WITH OCCASIONAL GAUZE LAYERS</u> | | <u>0</u> | <u>65</u> | <u>65</u> |

8. WELL CONSTRUCTION

Depth Drilled 65 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

| From | To | From | To |
|-----------------|---------------|----------------|------|
| <u>8</u> Inches | <u>0</u> Feet | <u>65</u> Feet | Feet |
| Inches | Feet | Feet | Feet |
| Inches | Feet | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>4.5</u> | <u>19</u> | <u>0.237</u> | <u>0</u> | <u>65</u> |

Perforations: Type perforation FACTORY SLOT
Size perforation 0.037

From 45 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 0.40' / 40.43'
Placement Method: Pumped Poured

Gravel Packed: Yes No
From 43 feet to 65 feet

9. WATER LEVEL
Static water level: feet below land surface
Artesian flow: G.P.M. P.S.I.
Water temperature: °F Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGHT
Address 731 PILOT RD Sta H
LAS VEGAS NV 89119
Contractor
Nevada contractor's license number
issued by the State Contractor's Board.
Nevada driller's license number issued by the M1869
Division of Water Resources, the on-site driller

7. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
G.P.M. Draw Down (feet Below Static) Time (Hours)
Date started DECEMBER 10 1996
Date completed DECEMBER 10 1996

Signed
By driller performing actual drilling on site or contractor
Date 2-11-97