DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 61497
Permit No.
Basin 205

1. OWNER Paul ~~[illegible]~~ Harris ADDRESS Moapa

S.W. corner

2. LOCATION S.W. ¼ N.W. ¼ Sec. 22 T. 14 N/S R. 66 E. M.D.B.&M. County

PERMIT NO. 25921

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Sandy		0	12	12
Clay		12	27	15
Sandy	X	27	32	05
Clay		32	36	04
Conglomerate of silts of Clay	X	36	99	

Date started March, 19 69
Date completed March, 19 69

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
approx	70 G.P.M.		
Bailer	test		

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 12 3/4 inches Total depth 99 feet
Casing record 8 3/4"
Weight per foot 10.75 Thickness 109 ga.

Diameter	From	To
8 3/4 inches	71 feet	99 - feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 38 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from 50 - feet to 99 feet

Perforations:
Type perforation Torch Cut
Size perforation 1/4" x 8" 4 Rounds
From 38' feet to 99 - feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 20 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ron Floyd Pump Co.
Address P.O. Box 157 Pahrump
Nevada contractor's license number 7479
Nevada driller's license number 476
Signed Terry E. Floyd
Date Feb 21st 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471