WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61534
Permit No.
Basin 110C

NOTICE OF INTENT NO. 30072

1. OWNER U S Army
MAILING ADDRESS Hwy 95 North Hawthorne NV
ADDRESS AT WELL LOCATION Hawthorne Army Depot

2. LOCATION SE ¼ NE ¼ Sec. 6 T 8N N/S R 30 E Mineral County
PERMIT NO. M01092 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other ARCH

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		G/L	17	17
Silty Clay	17	17	20	3
Sand		20	27	7

8. WELL CONSTRUCTION
Depth Drilled 27 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 3/4	Inches	G/L Feet	27 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40	PVC	G/L	15

Perforations:
Type perforation Cir Screen slot
Size perforation .010
From 15 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 11'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 11 feet to 27 feet

9. WATER LEVEL
Static water level 11.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Allen Winters
Address (Contractor) 1202 Kentucky Ave Woodland CA 95776
Nevada contractor's license number issued by the State Contractor's Board 12852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941
Signed Allen Winters (By driller performing actual drilling on site or contractor)
Date 11-13-96

Date started 11-8-96, 19
Date completed 11-8-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

MWIS-WADF 04