


Log No. 61586

Permit No. \_\_\_\_\_

Basin \_\_\_\_\_

**WELL DRILLER'S REPORT**

Please complete this form in its entirety



PRINT OR TYPE ONLY

1. OWNER GENE HALL ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SE 1/4 Sec. 11 T. 21 S. N/S R. 53 E NYE County  
 PERMIT NO. LOT 14 Block 9 JOYCELYN ESTATES Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	8	8
CALICHE		8	10	2
CLAY		10	15	5
CALICHE		15	17	2
CLAY		17	30	13
CALICHE		30	33	3
CLAY		33	57	24
CALICHE		57	61	4
CLAY		61	66	5
CALICHE	W.B.	66	70	4
CLAY		70	74	4
CALICHE	W.B.	74	76	2
CLAY		76	110	34
CALICHE	W.B.	110	116	6
CLAY		116	120	4
CALICHE	W.B.	120	121	1
CLAY		121	133	12
CALICHE	W.B.	133	135	2
CLAY		135	140	

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140 feet  
 Casing record 140' 8 5/8 OD  
 Weight per foot 14.11 Thickness .156  

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CONCRETE  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation FACTORY SAWCUT  
 Size perforation 1/8 X 3 INCH  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 9-15 1989  
 Date completed 9-18 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S+H Drilling Contractor  
 Address HCR 65 BOX 70906 Pahrump NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Thomas Brown  
 By driller performing actual drilling on site or contractor  
 Date 9-25-89