

Chg to 26370

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 61587
 Rec.
 Well No. 26370
 Permit No. 26370
 Do not fill in.

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Arriba Verde Ranch

Owner Dr. Robert Taylor Driller Allen Water Well Service Co.

Address 2020 West Charleston Blvd. Address 911 So. Main Street Lic. No. 40

Location of well: NW 1/4 NE 1/4 Sec. 23, T. 14 N/S, R. 69 E, in Clark County
 or Riverside, Nevada. #26370

Water will be used for Domestic and Farming Total depth of well 625'

Size of drilled hole 12" 0 to 250' & 9-5/8 250'-625' Weight of casing per linear foot

Thickness of casing .188 wall Temp. of water

Diameter and length of casing 6-5/8 O.D. 0 to 625'
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 61'

If flowing well describe control works
 (Type and size of valve, etc.)

Date of commencement of well 1/22/65 Date of completion of well 3/23/65

Type of well rig Rotary Rig.

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material	Water-bearing Formation, Casing Perforations, etc.
0	36	36	Sand, gravel and boulders	
36	68	32	sand, clay and gravel	
68	105	37	sand and gravel	Chief aquifer (water-bearing formation) from <u>68</u> to <u>105</u> ft.
105	290	185	sandy clay and gravel mixed	
290	425	135	clay, sand and gravel mixed with some coarse rock strata	Other aquifers <u>425-625</u>
425	485	60	pea gravel with streaks of cemented gravel	
485	625	140	cemented gravel with streaks of coarse sand and pea gravel	
				First water at <u>36</u> feet.
				Casing perforated from <u>425</u> to <u>625</u> ft.
				Size of perforations <u>4" x 6" on 12" centers</u> <u>4 around.</u>

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
6-5/8" OD	0	625	625	Casing cemented in place from 230' level up to 95' level.

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Allen Water Well Service Co.
Well Driller

By.....

License No. 40

Dated 3/26/65, 19.....

(Not to be filled in by Driller)
