

WELL DRILLER'S REPORT

Please complete this form in its entirety

Log No. 61592
 Permit No. _____
 Basin _____

NOTICE OF INTENT NO. 9043

PRINT OR TYPE ONLY

1. OWNER Charles Isehower ADDRESS AT WELL LOCATION Money St.
 MAILING ADDRESS _____

2. LOCATION SW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 11 T. 21s N/S R. 53 E. Nye County
 PERMIT NO. N/A 44-324-10 Joycelynn Estates Lot 4 Blk. 14
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	15'	15'
caliche		15'	17'	2'
clay		17'	62'	45'
caliche	WB	62'	70'	8'
clay		70'	75'	5'
caliche	WB	75'	77'	2'
clay		77'	90'	13'
caliche	WB	90'	95'	5'
clay		95'	100'	5'
caliche	WB	100'	107'	7'
clay		107'	115'	8'
caliche	WB	115'	117'	2'
clay		117'	130'	13'
caliche	WB	130'	134'	4'
clay		134'	140'	6'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140 x 8 5/8
 Weight per foot 16.94 Thickness 1.88

Diameter	From	To
<u>8 5/8</u> inches	<u>0'</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140' feet to 50' feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3"
 From 140' feet to 120' feet
 From _____ feet to _____ feet

RECEIVED

JAN 25 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 1-18, 1991
 Date completed 1-22, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 54 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling
Contractor
 Address HCR 65 Box 80358 Pahrump, Nv. 89041
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Samuel Brown
By driller performing actual drilling on site or contractor
 Date 1-22-91