

Log No. 61613
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 0656

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Nicholas Palazzo ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION 1/4 E 1/2 1/4 Sec 11 T 21S N/S R. 53 E Nye County _____
 PERMIT NO. BIF 6 lot 1 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name Joyce Lynn Estates

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Blue Clay</u>		<u>0</u>	<u>47</u>	<u>47</u>
<u>Blocky clay</u>	<u>X</u>	<u>47</u>	<u>49</u>	<u>2</u>
<u>Clay</u>		<u>49</u>	<u>125</u>	<u>76</u>
<u>Hard Blocky</u>	<u>X</u>	<u>125</u>	<u>132</u>	<u>7</u>
<u>Grey Clay w/ gravel</u>		<u>132</u>	<u>140</u>	<u>8</u>

8. WELL CONSTRUCTION
 Diameter hole 12 1/4 inches Total depth 140 feet
 Casing record 8 3/8 x 140
 Weight per foot _____ Thickness 15.6
 Diameter 8 3/8 inches From 0 feet To 140 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 140 feet

Perforations:
 Type perforation Torch
 Size perforation 1/2 x 6"
 From 100 feet to 140 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Custom Drilling inc Contractor
 Address 4475 Stacey Ave L.V. Contractor
 Nevada contractor's license number 19219
 Nevada contractor's drillers number _____
 Nevada driller's license number 1081
 Signed Bob Capshaw Actual Driller
 Contractor
 Date 12-4-83

Date started 11-2- 1983
 Date completed 11-2- 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

RECEIVED
 DEC 6 1983
 Div. of Water Resources
 Branch Office - Las Vegas, Nev.