WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 61719
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

In Book 335

1. OWNER Bob Deffen Derfer ADDRESS Pahrump Nev.

2. LOCATION SW ¼ SW ¼ Sec. 12 T. 21S N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	4	4
Cleche (Hard)		4	12	8
Fractured Cleche		12	20	8
Grey Clay		20	47	27
Cleche	X	47	57	10
Clay		57	97	40
Cleche	X	97	110	13
Reddish Clay		110	130	20
Fractured Cleche	XX	130	142	12

RECEIVED
1983
Div. of Water Resources
Water Office — Las Vegas, Nev.

Date started 9-23, 1983
Date completed 9-24, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 140 feet
Casing record 8 5/8 X 140
Weight per foot 14.56 Thickness 156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Torch
Size perforation 1/8 X 6 3 Rows
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 41 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Custom Drilling inc
Address 4425 Stacey Ave N.V
Nevada contractor's license number 19219
Nevada driller's license number 1081
Signed C.B. Capehart
Date

USE ADDITIONAL SHEETS IF NECESSARY

O-627