WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61726
Permit No.
Basin 162

1. OWNER Kenneth Banks ADDRESS Star Rt. 6615 Pahrump, NV 89041

2. LOCATION NE ¼ SW ¼ Sec. 16 T. 19 N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	12	12
brown clay		12	35	23
brown clay & gravel		35	55	20
soft brown clay		55	85	30
gravel		85	92	7
soft brown clay	x	92	155	63
brown clay		155	160	5

RECEIVED
JUL 30 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 7-12, 19 80
Date completed 7-15, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 3 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 160 feet
Casing record 8" casing 160' deep
Weight per foot 13½ lbs Thickness 10ga

Diameter	From	To
8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 3/8" x 8"
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 87 Feet below land surface 86
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg
Address Star Rt. 5231 Pahrump, NV 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 7-18-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627