WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

In Books

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61731
Permit No.
Basin 162

1. OWNER Jim Clark, Jr. ADDRESS P.O. Box 281 Pahrump, NV 89041

2. LOCATION SE ¼ NW ¼ Sec. 16 T. 19 ☒N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	10	10
brown soft clay		10	55	45
clay with gravel		55	72	17
brown clay		72	98	26
soft brown clay	x	98	148	50
brown clay		148	164	16
soft brown clay	x	164	180	16

RECEIVED
JUL 30 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 7-15, 19 80
Date completed 7-16, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down 0 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 180 feet
Casing record 8" casing 180' deep
Weight per foot 13½ lbs Thickness 10ga

Diameter	From	To
8 inches	0 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 3/8" X 8"
From 120 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 101 Feet below land surface 100
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg
Address Star Rt. 5231 Pahrump, NV 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 7-15-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627