



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1465

PRINT OR TYPE ONLY

Richard A. & Nancy Etter

OWNER Earl S. & Mary Evenson

MAILING ADDRESS 2071 E. Irwin Circle
Las Vegas, Nevada 89109

ADDRESS AT WELL LOCATION _____

2. LOCATION NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 17 T. 19-S N/S R. 53 E. Nye County

PERMIT NO. 41507

Issued by Water Resources

Parcel No.

Subdivision Name

3. TYPE OF WORK	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	4. PROPOSED USE	Domestic <input type="checkbox"/>	Irrigation <input checked="" type="checkbox"/>	Test <input type="checkbox"/>	5. TYPE WELL	Cable <input checked="" type="checkbox"/>	Rotary <input type="checkbox"/>
	Deepen <input type="checkbox"/>	Other <input type="checkbox"/>		Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>		Other <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
surface		0	4	4
silty clay		4	38	34
brown clay with gravel		38	56	18
white clay		56	70	14
brown clay with gravel		70	106	36
brown shale	x	106	116	10
brown clay with strips of hard shale	x	116	162	46
brown clay with gravel	x	162	200	38

RECEIVED

AUG 24 1983

Div. of Water Resources
 Branch Office — Las Vegas, Nev.

Date started August 16, 1983
 Date completed August 20, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 20 gals Draw down 4 feet $\frac{1}{4}$ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 200 feet
 Casing record 200ft. of 8 in casing
 Weight per foot 15 lbs. Thickness .156

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 200 feet

Perforations:

Type perforation torch cut
 Size perforation 3/8 in width 8 in long

From 130 feet to 200 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 92 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg
 Contractor

Address St. Rt. Box 5231
 Contractor

Nevada contractor's license number 7484

Nevada contractor's drillers number _____

Nevada driller's license number 725
 Actual Driller

Signed Charles Nyberg
 Contractor

Date Aug - 20 - 1983

