WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61882 In Book 1
Permit No.
Basin

1. OWNER Tom Christian ADDRESS

2. LOCATION SW ¼ NW ¼ Sec. 14 T. 21 S N/S R. 53 E. Nye County
PERMIT NO. Domestic

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
tan, white, br clay, cali stks.		0	15	15
tan, white, trace of brown clay		15	30	15
tan, white clay, cali stks.		30	45	15
" " "		45	60	15
tan, white clay, cali stks.				
+ br. clay		60	73	13
cali		73	75	2
tan, white clay, cali stks.		75	90	15
tan clay, cali stks.		90	105	15
tan, br. clay, cali stks.		105	120	15
cali stks.		120	122	2
tan - br. clay		122	127	5
Hard Pan		127	128	1
tan, br. clay, cali stks.		128	140	12

RECEIVED
SEP 15 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 8-29, 19 80
Date completed 9-2, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 140 feet
Casing record 8 5/8
Weight per foot ..... Thickness .156 wall

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐, Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation torch
Size perforation 1/8 by 12"
From 140' feet to 80' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 44' Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Floyd
Address Pahrump, Nev. 89041
Nevada contractor's license number 12344
Nevada driller's license number 588
Signed John Floyd
Date 9-3-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627