


Log No. 61940  
 Permit No. 162  
 Basin 162



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 9047

PRINT OR TYPE ONLY

1. OWNER Ray Lee ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 SE 1/4 Sec. 29 T. 19s N/S R. 53 E Nye County  
 PERMIT NO. N/A Issued by Water Resources | 27-381-25 Parcel No. | Parcel 4 Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	8'	8'
calichie		8'	10'	2'
clay		10'	14'	4'
calichie		14'	16'	2'
clay		16'	36'	20'
calichie		36'	40'	4'
clay		40'	55'	15'
calichie	WB	55'	58'	3'
clay		58'	66'	8'
calichie	WB	66'	69'	3'
clay		69'	74'	4'
calichie	WB	74'	76'	2'
clay		76'	88'	12'
calichie	WB	88'	92'	3'
clay		92'	118'	26'
calichie	WB	118'	123'	5'
clay		123'	129'	6'
calichie	WB	129'	134'	5'
clay		134'	140'	6'

8. WELL CONSTRUCTION  
 Diameter 1.2 1/2 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' x 8 5/8  
 Weight per foot 16.94 Thickness 1.88  

Diameter	From	To
<u>8 5/8</u> inches	<u>0'</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140' feet to 50' feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8 x 3"  
 From 140' feet to 120' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 JAN 25 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 1-18 1991  
 Date completed 1-22 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 42 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR65 Box 80358 Pahrump, Nv. 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada contractor's driller's number issued by the Division of Water Resources 1426  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Stamie Brown By driller performing actual drilling on site or contractor  
 Date 1-22-91

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours