WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61952
Permit No.
Basin 162

In Book

1. OWNER Bell Vista, Inc. ADDRESS P.O. Box 44 Pahrump, NV 89041

2. LOCATION SW ¼ SW ¼ Sec. 30 T. 19 N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface		0	6	6
soft brown clay		6	48	42
brown clay		48	68	20
soft brown clay	x	68	120	52

PERMIT 84257 65713 > Per Steve M.

RECEIVED
DEC 10 1979
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started 12-4- , 1979
Date completed 12-4 , 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 3 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 120 feet
Casing record 8" casing 120' deep
Weight per foot 13½ lbs Thickness 10GA

Diameter	From	To
8 inches	0 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 3/8" x8"
From 60 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 31 Feet below land surface 30
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg
Address Star Rt. 5231 Pahrump, NV 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 12-5-79

USE ADDITIONAL SHEETS IF NECESSARY

O 627