



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9208

PRINT OR TYPE ONLY

1. OWNER Frank Cork ADDRESS AT WELL LOCATION Garrison
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SW 1/4 Sec. 30 T. 19s N/S R. 53 E. Nye County
 PERMIT NO. N/A 28-249-7 Bellvista Unit 4 Lot 6
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	12'	12'
calichie		12'	14'	2'
clay		14'	18'	4'
calichie		18'	20'	2'
clay		20'	33'	13'
calichie		33'	35'	2'
clay		35'	41'	6'
calichie		41'	43'	2'
clay		43'	46'	3'
calichie		46'	48'	2'
clay		48'	54'	6'
calichie	WB	54'	56'	2'
clay		56'	58'	2'
calichie	WB	58'	62'	4'
clay		62'	73'	11'
calichie	WB	73'	78'	5'
clay		78'	93'	15'
calichie	WB	93'	95'	2'
clay		95'	110'	15'
calihcie	WB	110'	112'	2'
clay		112'	121'	9'
calichie	WB	121'	123'	2'
clay		123'	129'	6'
calichie	WB	129'	133'	4'
clay		133'	139'	6'
calichie	WB	139'	142'	3'
clay		142'	149'	7'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 160' feet
 _____ inches
 _____ inches
 Casing record 160' x 8 5/8
 Weight per foot 16.94 Thickness 1.88

Diameter	From	To
<u>8 5/8</u> inches	<u>0'</u> feet	<u>160'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 160' feet to 50' feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-26 1991
 Date completed 5-2 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
MAY 08 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 43 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling
Contractor
 Address HCR 65 Box 80358 Pahrump, Nv. 89041
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
By driller performing actual drilling on site or contractor
 Date 5-2-91

