WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61978
Permit No.
Basin
NOTICE OF INTENT NO. 14616

1. OWNER Doris Reno
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6451 S. Elizabeth

2. LOCATION SE ¼ NE ¼ Sec. 14 T. 21S N/S R. 53 E Nye County
PERMIT NO. Issued by Water Resources | 44-633-13 Parcel No. | Stardust Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	13	9
Calichie		13	16	3
Clay		16	24	8
Calichie		24	26	2
Clay		26	38	12
Calichie		38	46	8
Clay		46	53	7
Calichie	WB	53	57	4
Clay		57	64	7
Calichie	WB	64	66	2
Clay		66	77	10
Calichie	WB	77	80	3
Clay		80	91	11
Calichie	WB	91	93	2
Clay		93	102	9
Calichie	WB	102	105	3
Clay		105	113	8
Calichie	WB	113	116	3
Clay		116	122	6
Calichie	WB	122	124	2
Clay		124	133	9
Calichie	WB	133	136	3
Clay		136	140	4

RECEIVED
MAY 08 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started April 14, 1995
Date completed April 17, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 18" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 5-1-95

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627