WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61995
Permit No.
Basin
NOTICE OF INTENT NO. 16950

1. OWNER Saul Villa
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1240 Carson

2. LOCATION SW ¼ NW ¼ Sec. 14 T. 21 S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 44-121-08 (Parcel No.) Mesa Oeste (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	1	1'
Caliche		1	3	2'
Clay		3	12	9'
Caliche		12	14	2'
Clay		14	31	17'
Caliche		31	33	2'
Clay		33	50	17'
Caliche	WB	50	52	2'
Clay		52	67	15'
Caliche	WB	67	69	2'
Clay		69	77	8'
Caliche	WB	77	80	3'
CLAY		80	90	10'
Caliche	WB	90	95	5'
CLAY		95	114	19'
Caliche	WB	114	116	2'
CLAY		116	129	13'
Caliche	WB	129	132	3'
CLAY		132	138	6'
Caliche	WB	138	140	2'

DCNR/DWR Received MAR 5 1996 LAS VEGAS OFFICE

Date started 1-29, 19 96
Date completed 1-29, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 ¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. box 4220 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 2-27-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627