WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

1" Back

Please complete this form in its entirety

Log No. 62037 ONLY
Permit No.
Basin 162

1. OWNER Ray Wulfenstein ADDRESS P.O. Box 38A Pahrump
Lot 1 Block G Tumbleweed Ranchos
2. LOCATION NW ¼ SE ¼ Sec. 30 T. 19 ~~N~~/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	4	4
Caliche		4	14	10
Red Shale		14	22	8
Granulated Shale		22	27	5
Red Clay		27	58	31
Red Shale		58	62	4
Red Shale & White Shale		62	78	16
Brown Clay and		78		
White Shale	yes		120	42

RECEIVED
MAR 5 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 2-14, 19 79
Date completed 2-16, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 ¼ inches Total depth 120 feet
Casing record
Weight per foot 12 Thickness 10 Ga.

Diameter	From	To
8 5/8 inches	0 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Burned
Size perforation ~~0.20~~ 1/8"
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface 28½
Flow G.P.M.
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name C. B. Capehart
Address 4425 Stacey
Nevada contractor's license number
Nevada driller's license number 1081
Signed C. B. Capehart
Date 2-19-79

USE ADDITIONAL SHEETS IF NECESSARY

5471