



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Perry Bowmen ADDRESS Patrum NW

2. LOCATION S.W. 1/4 S.E. 1/4 Sec. 3 T. 21 N. SR. 54 E Clark County
PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	12	12
white clay (matrix w/ gravel)		12	70	58
brown clay		70	118	48
large gravel & sand	✓	118	124	6
clay w/ embedded gravel		124	142	38
gravel and sand	✓	142	148	6
brown clay		148	205	37
light brown clay w/ gravel		205	220	15
brown clay		220	242	22
sand & gravel	✓	242	245	3
clay w/ gravel		245	288	43
sand & gravel		288	291	3
brown clay		291	300	9

8. WELL CONSTRUCTION

Diameter hole 8" inches Total depth 300' feet
 Casing record 300' 8"
 Weight per foot 13 lbs Thickness 10 ga.

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>300</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet

Perforations:
 Type perforation torch cut
 Size perforation 3/8" x 8"
 From 130 feet to 300 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

RECEIVED

MAR 4 1974

Div. of Water Resources
Branch Office - Las Vegas, Nev.

Date started 1-15, 1974
Date completed 1-19, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 72 Feet below land surface 73
 Flow..... G.P.M.
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Nyberg Well Drilling
 Address Box 801 B Patrum NW
 Nevada contractor's license number 7484
 Nevada driller's license number 725
 Signed Charles Nyberg
 Date 2-29-74