



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1612

PRINT OR TYPE ONLY

1. OWNER Vera Murphy ADDRESS AT WELL LOCATION
 MAILING ADDRESS Pahrump Nev. 89041

2. LOCATION SE ¼ SE ¼ Sec. 31 T. 19-S N/S R. 53 E Nye County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK 4. PROPOSED USE 5. TYPE WELL
 New Well Recondition Domestic Irrigation Test Cable Rotary
 Deepen Other Municipal Industrial Stock Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
White Clay		4	12	8
Light Brown Clay		12	32	20
Soft Brown Clay	x	32	68	36
Brown Clay	x	68	140	72

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 140 feet
 Casing record 140 ft. of 8 in casing
 Weight per foot 15 lbs. Thickness 156
 Diameter From To
 8 inches 0 feet 140 feet
 Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from feet to feet
 Perforations:
 Type perforation torch cut
 Size perforation 3/8 in width 8 in long
 From 80 feet to 140 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

RECEIVED

MAR 5 1984

Div. of Water Resources
 Branch Office - Las Vegas, Nev.

Date started February 21, 1984
 Date completed February 21, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 33 feet below land surface
 Flow G.P.M. P.S.I.
 Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address ST. RT. BOX 5231 Contractor
 Nevada contractor's license number 7484
 Nevada contractor's drillers number
 Nevada driller's license number 725 Actual Driller
 Signed *Charles Nyberg* Contractor
 Date February 22, 1984

BAILER TEST
 G.P.M. 20 gals. Draw down 4 feet 1/4 hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours