WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 62134
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8829

1. OWNER Ralph Nelson
MAILING ADDRESS
ADDRESS AT WELL LOCATION Leslie & tough boy

2. LOCATION NE ¼ SE ¼ Sec. 31 T. 19s N/S R. 53 E NYE County
PERMIT NO. N/A Issued by Water Resources | 29-572-09 Parcel No. | Lot 77 Gooseneck Park Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	10'	10'
calichie		10'	11'	1'
clay		11'	38'	27'
calichie		38'	41'	3'
clay		41'	53'	12'
calichie	WB	53'	55'	2'
clay		55'	67'	12'
cal;ichie	WB	67'	69'	2'
clay		69'	74'	5'
calichie	WB	74'	78'	4'
clay		78'	83'	5'
calichie	WB	83'	86'	3'
clay		86'	118'	32'
calichie	WB	118'	120'	2'
clay		120'	131'	11'
calichie	WB	131'	136'	5'
clay		136'	140'	4'

RECEIVED
DEC 07 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-21-, 19 90
Date completed 11-30, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140' feet
inches
inches
Casing record 140' x 8 5/8"
Weight per foot 16.94 Thickness .188

Diameter	From	To
8 5/8" inches	0 feet	140' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation factory sawcut
Size perforation 1/8" x 3"
From 140' feet to 120' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING Contractor
Address HCR 65 box 80358 Pahrump, Nv 89041 Contractor
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] By driller performing actual drilling on site or contractor
Date

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627