



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Pete Peterson ADDRESS P.O. Box Pahump neck  
2. LOCATION S.W. 1/4 S.W. 1/4 Sec. 31 T. 19 N/S.R. 53 E. Nye County  
PERMIT NO. Domestic

3. TYPE OF WORK:  New Well,  Recondition,  Deepen,  Other  
4. PROPOSED USE:  Domestic,  Irrigation,  Test,  Municipal,  Industrial,  Stock  
5. TYPE WELL:  Cable,  Rotary,  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Caliche		5	18	13
Sandy clay	✓	18	22	04
Caliche	✓	22	25	03
Brassy clay		25	28	03
Hard Caliche	✓	28	32	04
Brassy clay		32	38	06
Hard Caliche	✓	38	39	01
Brassy clay		39	45	06
Sandy clay	✓	45	48	03
Brassy clay		48	68	20
Sandy clay	✓	68	80	12
Brn Sandy clay	✓	80	120	40

8. WELL CONSTRUCTION  
Diameter hole 12 3/4 inches Total depth 120 feet  
Casing record 8 5/8  
Weight per foot 12-50 Thickness 109 lbs  
Diameter 8 5/8 inches From ±1 feet To 120 feet  
Surface seal:  Yes  No Type Cement  
Depth of seal 50 feet  
Gravel packed:  Yes  No  
Gravel packed from 50 feet to 120 feet  
Perforations:  
Type perforation Teach Cut  
Size perforation 1 1/4" x 8" x 3 Rounds  
From 60 feet to 120 feet

RECEIVED  
MAR 31 1972  
DIV. OF WATER RESOURCES  
BRANCH OFFICE  
LAS VEGAS, NEVADA

9. WATER LEVEL  
Static water level 19 Feet below land surface 19  
Flow G.P.M.  
Water temperature ° F. Quality good

Date started Oct 29, 1971  
Date completed Nov 3, 1971

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Ron Floyd Pump Co  
Address P.O. Box 157 Pahump  
Nevada contractor's license number 7479  
Nevada driller's license number 476  
Signed Ronny E. Floyd  
Date 10-27-71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
G.P.M. approx 50 Draw down 35 feet 30 min hours  
G.P.M.  Draw down  feet  hours  
G.P.M.  Draw down  feet  hours