



**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1502

PRINT OR TYPE ONLY

1. OWNER Phil & Melba Sylvester ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Fahrump, Nev. 89041 \_\_\_\_\_

2. LOCATION NE  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 12 T. 20-S N/S R. 52 E Nye County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material        | Water Strata | From | To  | Thick-ness |
|-----------------|--------------|------|-----|------------|
| Surface         |              | 0    | 6   | 6          |
| White Clay      |              | 6    | 14  | 12         |
| Gray Clay       |              | 14   | 34  | 20         |
| Soft Brown Clay | x            | 34   | 72  | 38         |
| Brown Clay      | x            | 72   | 102 | 30         |
| Gray Clay       | x            | 102  | 124 | 22         |
| Brown Clay      | x            | 124  | 140 | 16         |

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 140 feet  
 Casing record 140 ft. of 8 in. casing  
 Weight per foot 15 lbs. Thickness 156  
 Diameter From To  
8 inches 0 feet 140 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 140 feet  
 Perforations:  
 Type perforation torch cut  
 Size perforation 3/8 in width 8 in. long  
 From 80 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED

NOV 18 1983

Div. of Water Resources  
 Branch Office - Las Vegas, Nev

9. WATER LEVEL  
 Static water level 32 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F. Quality \_\_\_\_\_

Date started November 15, 19 83  
 Date completed November 15, 19 83

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address St. Rt. Box 5231 Contractor  
 Nevada contractor's license number 7484  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 725 Actual Driller  
 Signed Charles Nyberg Contractor  
 Date 11/16/83

BAILER TEST  
 G.P.M. 20 gals Draw down 4 feet 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours