

OFFICE USE ONLY  
 Log No. 62303  
 Permit No. \_\_\_\_\_  
 Basin 16a

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17582

1. OWNER Keith & Joyce Benson ADDRESS AT WELL LOCATION 3481 W. Dyer St.  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 NE 1/4 Sec 13 T 20-S N/S R 52 E Nye County \_\_\_\_\_  
 PERMIT NO. 41-411-16 Golden Springs Ranch Unit: 1  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brn clay		4	8	4
Gray clay		8	24	16
Brn clay		24	62	38
Brn clay/caliche	X	62	86	24
Brn clay	X	86	117	31
Brn clay/caliche		117	130	13
Brn clay		130	140	10

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4" width 8" long  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet



Date started January 15, 1996  
 Date completed January 15, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

9. WATER LEVEL  
 Static water level 4.4 feet below surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jim Pike Well Drilling, LLC Contractor  
 Address P.O. Box 56 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 17563A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date January 19, 1996