



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14815

1. OWNER Charles Grenier ADDRESS AT WELL LOCATION 3171 W. Retread
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SE 1/4 Sec. 13 T. 20-S N/S R. 52 E. Nye County Nye
 PERMIT NO. 28-642-07 Parcel No. _____ Subdivision Name Charleston Park Ranchos, Unit 1
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Gray clay		4	26	22
Brown clay		26	52	26
Brown clay/caliche	X	52	68	16
Brown clay		68	104	36
Brown clay/caliche	X	104	122	18
Brown clay		122	140	18

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
 Type perforation 1/Torch Cut - 1/Factory Cut
 Size perforation 1" width 8" long - 1/8" width 3" long -
 From 100 feet to 140 feet 8 rolls
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

RECEIVED
 MAY 01 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 46 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started April 21, 1995
 Date completed April 21, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources / the on-site driller 1812
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 25, 1995