WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62371
Permit No.
Basin 162

NOTICE OF INTENT NO. 16941

1. OWNER Marty Daffer
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4861 Paiute

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) | Parcel No. 45-291-05 | Subdivision Name Green Saddle Ranch

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Calichie		5	7	2
Clay		7	13	6
Calichie		13	16	3
Clay		16	29	13
Calichie		29	32	3
Clay		32	44	12
Calichie		44	46	2
Clay		46	54	8
Calichie		54	57	3
Clay		57	65	8
Calichie	WB	65	68	3
Clay		68	76	8
Calichie	WB	76	81	5
Clay		81	89	8
Calichie	WB	89	94	5
Clay		94	99	5
Calichie	WB	99	105	6
Clay		105	116	11
Calichie	WB	116	119	3
Clay		119	127	8
Calichie	WB	127	129	2
Clay		129	135	6
Calichie	WB	135	138	3
Clay		138	140	2

RECEIVED FEB 21 1996 LAS VEGAS OFFICE

Date started January 19, 19 96
Date completed January 22, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) P.O. Box 4220
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 1-26-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627