

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34600

1. OWNER U S Army ADDRESS AT WELL LOCATION Hawthorne Army Depot
 MAILING ADDRESS Box 95 North Hawthorne NV
 2. LOCATION NE 1/4 SW 1/4 Sec 23 T 8N N/S R 30 E Mineral County
 PERMIT NO. MD 1092 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other ARCH

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty sand		G/L	45	45
Sand w/ TR Gravel				
Sandy clay				
Sand w/ TR silt				
Sand				
Sandy clay				
Sand				
Silty sandy clay				
Sand	177	175	197	22
Silty clay		197	199	2
Sand		199	215	16
Sandy clay		215	221	6
Silty sand		221	237	16

8. WELL CONSTRUCTION
 Depth Drilled 237 Feet Depth Cased 235 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 3/4 Inches To 6 1/2 Feet 237 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 80	PVC	G/L	230

 Perforations:
 Type perforation Circumslot
 Size perforation .060
 From 230 feet to 235 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 226 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 226 feet to 237 feet

Date started 11-12 1996
 Date completed 11-13 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 176.9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Allen Winter Contractor
 Address 202 Kentucky Ave Contractor
Woodland CA 95776
 Nevada contractor's license number 12852
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1941
 Division of Water Resources, the on-site driller
 Signed Allen Winter
 By driller performing actual drilling on site or contractor
 Date 11-21-96