


OFFICE USE ONLY
 Log No. 62443
 Permit No. _____
 Basin. 1370



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31384

1. OWNER JAMES TACKETT / North American Builders
 MAILING ADDRESS PO Box 1124
ROUND MTN NEV 89045
 ADDRESS AT WELL LOCATION ONE Block NORTH
EAST OF Cowboy COURT.

2. LOCATION NW 1/4 SW 1/4 Sec. 4 T. 10 N/S R. 43 E NYE County
 PERMIT NO. 12-461-47 Parcel No. SEMITA Subdivision Name COURTS
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DARK BRN CLAY		0	12	12
LARGE GRAVEL		12	20	8
WHITE CLAY		20	24	4
TAN CLAY		24	38	14
SMALL GRAVEL & SAND		38	41	3
GRAY CLAY		41	43	2
LARGE GRAVEL		43	46	3
BROWN CLAY		46	55	9
SMALL GRAVEL & SAND		55	60	5
BROWN CLAY		60	69	9
SAND		69	73	4
BROWN CLAY		73	86	13
SMALL GRAVEL & SAND	✓	86	97	11
DARK BRN CLAY		97	107	10
LARGE GRAVEL	✓	107	126	19
YELLOW CLAY		126	130	4

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 130 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.8</u>	<u>.188</u>	<u>0+1</u>	<u>130</u>

Perforations:
 Type perforation MILLED SLOT
 Size perforation 3/4" 64 slots P/F
 From 105 feet to 125 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 5 feet below land surface
 Artesian flow NO G.P.M. 60 P.S.I.
 Water temperature COLD °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LES WOYTEK - WOYTEK DRILLING CO. INC. Contractor
 Address 2720 STOWE DRIVE Contractor
RENO NEVADA 89511
 Nevada contractor's license number issued by the State Contractor's Board 024521
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M. Havia
 By driller performing actual drilling on site or contractor
 Date 10-26-96

Date started 10-24, 1996
 Date completed 10-25, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60+</u>	<u>NA</u>	<u>4 HRS</u>