

OFFICE USE ONLY  
 Log No. 62451  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28062

1. OWNER Chuck Payne ADDRESS AT WELL LOCATION 251 Apple Creek  
 MAILING ADDRESS 4021 Foothills Rd. Gardnerville NV. Gardnerville NV.

2. LOCATION NW 1/4 SW 1/4 Sec. 3 T. 12 S. R. 19 E. Douglas County  
 PERMIT NO. 19-390-12 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Course Sands</u>		<u>0</u>	<u>25</u>	<u>25</u>
<u>Boulders and DF Sands</u>		<u>25</u>	<u>46</u>	<u>21</u>
<u>Brown Sands and Clay</u>		<u>46</u>	<u>53</u>	<u>7</u>
<u>Course DF Sands</u>		<u>53</u>	<u>110</u>	<u>57</u>
<u>Course Sands and Boulders</u>	<del>XX</del>	<u>110</u>	<u>150</u>	<u>40</u>

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 1/8 Inches 0 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>150</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3x 7/32  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 100 feet to 150 feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 251 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.H. Pump Co. Contractor  
 Address 5551 Hwy 50 E #3 Contractor  
Carson City NV. 89701

Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael Black  
 By driller performing actual drilling on site or contractor  
 Date 10-25-96

Date started 10-23, 19 96  
 Date completed 10-25, 19 96

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25+</u>	<u>45</u>	<u>3 HRS</u>	

RECEIVED  
 96 OCT 25 PM 4:03  
 STATE ENGINEERS OFFICE