

OFFICE USE ONLY  
 Log No. 62466  
 Permit No. 162  
 Basin 162

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 8617  
 Basin Rd

PRINT OR TYPE ONLY

1. OWNER J.B. Kirk ADDRESS AT WELL LOCATION Basin Rd  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 NW 1/4 Sec 14 T 20S N/S R 52 E NYE County Golden Springs Ranch Unit 3 Lot 4  
 PERMIT NO. N/A Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	10'	10'
caliche		10'	13'	3'
clay		13'	19'	6'
caliche		19'	33'	14'
clay		33'	40'	7'
caliche		40'	42'	2'
clay		42'	58'	16'
caliche	WB	58'	63'	5'
clay		63'	70'	7'
caliche	WB	70'	74'	4'
clay		74'	82'	8'
caliche	WB	82'	88'	6'
clay		88'	99'	11'
caliche	WB	99'	112'	13'
clay		112'	125'	13'
caliche	WB	125'	128'	3'
clay		128'	131'	3'
caliche	WB	131'	140'	9'

RECEIVED  
 JAN 25 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' X 8 5/8"  
 Weight per foot 14.11 Thickness .156  
 Diameter From To  
8 5/8" inches 0 feet 140 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8" x 3"  
 From 140 feet to 120' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-27 1990  
 Date completed 12-31 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING  
 Address HCR 65 BOX 80358  
PAHRUMP, NEVADA  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1426  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1573  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-21-91