WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62473
Permit No.
Basin

NOTICE OF INTENT NO. 14598

1. OWNER Pahrump Properties
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2110 Prospector

2. LOCATION SE ¼ SE ¼ Sec. 14 T. 20S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 26-741-84 (Parcel No.) Charleston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	14	14
Calichie		14	16	2
Clay		16	19	3
Calichie		19	24	5
Clay		24	35	11
Calichie		35	38	3
Clay		38	47	9
Calichie		47	50	3
Clay		50	64	14
Calichie	WB	64	67	3
Clay		67	74	7
Calichie	WB	74	77	3
Clay		77	84	7
Calichie	WB	84	87	3
Clay		87	99	12
Calichie	WB	99	104	5
Clay		104	112	8
Calichie	WB	112	115	3
Clay		115	123	8
Calichie	WB	123	126	3
Clay		126	133	7
Calichie	WB	133	137	4
Clay		137	140	3

RECEIVED
APR 25 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started March 27, 19 95
Date completed March 29, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 8" x 1/3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dem (By driller performing actual drilling on site or contractor)
Date 4/11/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627