

WELL DRILLER'S REPORT

Please complete this form in its entirety

Permit No. 162
Basin 162
NOTICE OF INTENT NO. 8656

PRINT OR TYPE ONLY

1. OWNER ELGIN BRUNER ADDRESS AT WELL LOCATION PANAVICH-OFT CHAS. PENNY
MAILING ADDRESS 3950 STIENBECK DR PAHRUMP, NEV 89041
LAS VEGAS, NEV 89115
2. LOCATION SE 1/4 Sec 23 T 20 N/S R 52 E NYE County
PERMIT NO. 1 MAP 243204 Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Br. Clay		0	3	3
GRAY CLAY		3	7	4
WHITE CLAY		7	32	25
SANDY WHITE CLAY	x	32	35	3
Cakechi		35	37	2
light Br. Clay		37	95	58
SANDY BR. CLAY	x	95	100	5
Sticky Br. Clay		100	110	10
Cakechi		110	112	2
SANDY GRAY CLAY	x	112	140	28
GRAY CLAY		140	150	10

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 150 feet
Casing record 8"
Weight per foot Thickness 188
Diameter From To
8 inches 0 feet 151 feet
Surface seal: Yes No Type CEMENT GROUT
Depth of seal 551 feet
Gravel packed: Yes No
Gravel packed from 55 feet to 150 feet
Perforations:
Type perforation factory cut
Size perforation 1/8 x 3
From 110 feet to 130 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DM Gullard Drilling Contractor
Address 6022 So Euc Lid Ave - LV, NV 89120 Contractor
Nevada contractor's license number 4796
issued by the State Contractor's Board
Nevada contractor's driller's number 115
issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed DM Gullard
By driller performing actual drilling on site or contractor
Date 4-25-91

Date started 4-8 1991
Date completed 4-16 1991

WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 30 feet 1/2 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

RECEIVED
APR 2 1991
Water Resources
Branch Office - Las Vegas, NV

