WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62620
Permit No.
Basin 163

NOTICE OF INTENT NO. 14667

1. OWNER EDWARD KOLOJAY
MAILING ADDRESS 9124 SUNDIAL Dr.
LAS VEGAS, NV. 89134

ADDRESS AT WELL LOCATION SANDY VALLEY

2. LOCATION NE ¼ NE ¼ Sec. 6 T. 25 S N/S R. 57 E. CLARK County
PERMIT NO. 590-330-092 (Issued by Water Resources) Parcel No. 219-06-501-022 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	28	28
CALICHIE		28	33	5
CLAY		33	51	18
CALICHIE	W.B	51	58	7
CLAY		58	63	5
CALICHIE	W.B	63	66	3
CLAY		66	74	8
CALICHIE	W.B	74	77	3
CLAY		77	96	19
CALICHIE	W.B	96	103	7
CLAY		103	112	9
CALICHIE	W.B	112	117	5
CLAY		117	120	3

RECEIVED
APR 25 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-29, 1995
Date completed 4-1, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	120

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	120

Perforations:
Type perforation FACTORY SAWCUT
Size perforation 1/8 INCH BY 3 INCH
From 120 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 120 feet to 50 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR. 78 BOX 80358 (Contractor)
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 4-1-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627