

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14805

1. OWNER Walter Baumgarten ADDRESS AT WELL LOCATION 3100 Parkridge
 MAILING ADDRESS _____

2. LOCATION NE 1/4 NW 1/4 Sec. 36 T 20-S N/S R 53 E Nye County
 PERMIT NO. 41-011-19 Calvada Valley Unit 2
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Sandy loam		4	10	6
Brown clay		10	26	16
Brown clay/caliche		26	32	6
Brown clay		32	54	22
Brown clay/caliche		54	65	11
Limestone		65	70	5
Brown clay/caliche	X	70	85	15
Brown clay		85	104	19
Brown clay/caliche	X	104	152	48
Brown clay		152	160	8

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
 Type perforation 1/Torch Cut - 1/Factory Cut
 Size perforation 1" width 8" long - 1/8" width 3" long
 From 120 feet to 160 feet 8 rolls
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

RECEIVED
 MAY 01 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 69 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started April 17, 1995
 Date completed April 17, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM PIKE WELL DRILLING, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041

Nevada contractor's license number 17563A
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1812
 Division of Water Resources, the on-site driller

Signed Jim A. Pike
 By driller performing actual drilling on site or contractor
 Date April 21, 1995