DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 62707
Permit No.
Basin 162

1. OWNER Cafrodo Test well ADDRESS Pahrump, Nev. Elwart place

2. LOCATION N.W. ¼ SE ¼ Sec. 31 T. 20 N/S R. 54 E. Nye County
PERMIT NO. TEST WELL No Food

3. TYPE OF WORK				4. PROPOSED USE				5. TYPE WELL	
New Well	☒	Recondition	☐	Domestic	☒	Irrigation	☐	Test	☐
Deepen	☐	Other	☐	Municipal	☐	Industrial	☐	Stock	☐
								Cable ☐	Rotary ☒
								Other ☐	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2'	2'
Sandy clay		2'	16'	14'
B-clay		16'	32'	16'
Calichie		32'	33'	1'
Sandy clay		33'	38'	5'
Soft clay		38'	42'	4'
B-clay		42'	49'	7'
Calichi		49'	52'	3'
Sandy clay		52'	72'	20'
Clay		72'	79'	7'
Sandy clay		79'	82'	3'
Calichie		82'	85'	3'
Sandy clay		85'	95'	10'
Calichie		95'	100'	5'
B-clay		100	120'	20'
W-clay		120	128'	8'
Soft w/ clay		128	138'	10'
Calichie		138'	142'	4'
Sandy clay		142'	172	30'
Calichi		172'	174	2'
Sandy clay		174'	194'	20'
Soft w/ clay		194'	209'	15'
Calichi		209	212'	3'
Sandy clay		212	229	17'
Soft clay		229'	239	10'
B-clay		239	242	3'
Sandy clay		242	250'	8'

Water Strata: Well was capped and not used; Well was capped and not used; Used for water test

Date started 3-18-, 1976
Date completed 3-30-, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
APR 26 1976
Div. of Water Resources
Water Rights Office — Las Vegas, Nev.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 12¼ inches Total depth 250 feet
Casing record
Weight per foot 12.75 Thickness .10

Diameter		From		To	
8 5/8	inches	0	feet	130	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 120 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from 120 feet to 130 feet

Perforations:
Type perforation Tack Cut
Size perforation ¼" x 8" # round
From 120 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 72 Feet below land surface 72
Flow G.P.M.
Water temperature ° F. Quality Bad

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne L. Floyd Pump.
Address P.O. Box 320.
Nevada contractor's license number 12344
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 4-5-76

USE ADDITIONAL SHEETS IF NECESSARY

5471