



OFFICE USE ONLY  
 Log No. 62804  
 Permit No. 212  
 Basin. 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17261

1. OWNER Coast Hotels & Casinos ADDRESS AT WELL LOCATION 4300 West Carey,  
910 Broadbent 833 Nevada No. Las Vegas, NV  
Hwy, #3, Boulder City, NV 89005  
 2. LOCATION SE 1/4 SW 1/4 Sec. 18 T. 20 N. R. 61 E. CLARK County  
 PERMIT NO. MD-2779 139-18-404-001 Parcel No. N/A Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILTY SAND		0	3	3
CALICHE		3	6	3
GRAVEL		6	8	2
CALICHE		8	16	8
GRAVEL		16	18	2
SILTY SAND		18	19	1
CALICHE	21	19	21	3
CLAY		21	26	5
CALICHE		26	27.5	1.5

8. WELL CONSTRUCTION  
 Depth Drilled 28 Feet Depth Cased 27.5 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 28 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 1/4</u>		<u>1/8</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation Sawcut  
 Size perforation 0.020  
 From 25 feet to 27.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 21  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No w/ 3% bentonite  
 From 23 feet to 28 feet

9. WATER LEVEL  
 Static water level 21 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started February 20, 1997  
 Date completed February 20, 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Weber Drilling Services Contractor  
 Address 115 So. Weber Dr Suite 1 Contractor  
Chandler Az 85226  
 Nevada contractor's license number issued by the State Contractor's Board 39528  
 Nevada driller's license number issued by the Division of Water Resources 11847  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2-20-97