

OFFICE USE ONLY
 Log No. 62815
 Permit No. _____
 Basin. 21a

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17261

1. OWNER Coast Hotels & Casinos ADDRESS AT WELL LOCATION 4300 W Carey,
 MAILING ADDRESS 10 Broadbent 833 Nevada Ave. Las Vegas
 Hwy, #3, Boulder City, NV 89005
 2. LOCATION SE 1/4 SW 1/4 Sec. 18 T. 20 N. R. 101 E. CLARK County
 PERMIT NO. MO-2779 139-18-404-001 Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From Ft	To Ft	Thickness Ft
SILTY SAND		0	3	3
CALICHE		3	6	3
GRAVEL		6	8	2
CALICHE		8	16	8
GRAVEL		16	18	2
SILTY SAND		18	19	1
CALICHE	21'	19	21	3
CLAY		21	26	5
CALICHE		26	27.5	1.5

8. WELL CONSTRUCTION
 Depth Drilled 27.5 Feet Depth Cased 27.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 27.5
 Inches Feet Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 1/4</u>		<u>1/8</u>	<u>0</u>	<u>25</u>

Perforations:
 Type perforation Sawcut
 Size perforation 0.020
 From 25 feet to 27.5 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 21'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No w/ 3% bentonite
 From 23 feet to 27.5 feet

9. WATER LEVEL
 Static water level 21 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started February 17 1997
 Date completed February 17 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Weber Drilling Services Contractor
 Address 115 So. Weber Dr Suite 1 Chandler, Az 85226 Contractor
 Nevada contractor's license number 39528 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11-1847
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 3-2-97