

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT **B**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 172101

1. OWNER Coast Hotels & Casinos ADDRESS AT WELL LOCATION 4300 West Carey, No. Las Vegas  
 MAILING ADDRESS 60 Broadbent #33  
Nevada Hwy, Boulder City, NV  
 2. LOCATION SE 1/4 SW 1/4 Sec 18 T 20 N R 1 E CLARK County  
 PERMIT NO. MO-2779 Issued by Water Resources Parcel No. 139-18-404-001 Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From ft	To ft	Thickness ft
SILTY SAND		0	3	3
CALICHE		3	6	3
GRAVEL		6	8	2
CALICHE		8	16	8
GRAVEL		16	18	2
SILTY SAND		18	19	1
CALICHE		19	20	1

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 20 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/4</u>		<u>1/8</u>	<u>0</u>	<u>10</u>

Perforations:  
 Type perforation Sawcut  
 Size perforation 0.020  
 From 10 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
w/ 3% bentonite  
 Gravel Packed:  Yes  No  
 From 8' feet to 20' feet

Date started February 18, 1997  
 Date completed February 18, 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Weber Drilling Services Contractor  
 Address 115 So. Weber Dr. Suite 1 Contractor  
Chandler, Az 85226  
 Nevada contractor's license number issued by the State Contractor's Board 39528  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1847  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-6-97