WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62831
Permit No.
Basin 162

NOTICE OF INTENT NO. 15512

1. OWNER SCC INC
MAILING ADDRESS 3680 S. National
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3680 S. National Pahrump, Nev. 89048

2. LOCATION SE 1/4 SE 1/4 Sec. 31 T 20S N/S R 54E E Nye County
PERMIT NO. Issued by Water Resources | 41-161-15 Parcel No. | Calvada Valley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Silt		0	19	19
Light Brown Silt		19	37	18
Light Brown Silt		37	56	19
White Calichia	x	56	75	19
Brown Sandy Loam	x	75	96	21
Brown Clay	x	96	114	18
Light Brown Clay	x	114	130	16
Light Brown Clay Sand	x	130	148	18
See next line	x	148	155	7
Light Brown Clay Sand and Gravel				

Date started 2/25/97 , 19__
Date completed 2/25/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4 Inches		0 Feet	155 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	155

Perforations:
Type perforation TORCH
Size perforation .25 x 6
From 110 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 90 feet to 155 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date