

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 62834
 Permit No. _____
 Basin 16a

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15805

1. OWNER BRIAN WARD ADDRESS AT WELL LOCATION 3431 W. WILSON AVENUE
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec 13 T 20-S N/S R 52 E NYE County _____
 PERMIT NO. 28-653-06 CHARLESTON PARK RANCHOS UNIT 1
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown clay		4	8	4
Gray clay & caliche		8	18	10
Green clay		18	29	11
Gray clay		29	46	17
Brown clay & caliche	x	46	68	22
Brown clay		68	94	26
Brown clay & caliche		94	108	14
Brown clay	x	108	140	32

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
 Type perforation Torch cut
 Size perforation 1" width 8" long
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level: 47 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.F.
 Water temperature _____ °F Quality _____

Date started March 4, 1997
 Date completed March 4, 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>4</u>	<u>1/4</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim Pike Well Drilling, LLC
Contractor
 Address P.O. Box 56
Contractor
Pahrump, Nevada 89041

Nevada contractor's license number issued by the State Contractor's Board: 17563A
 Nevada driller's license number issued by the Division of Water Resources (the on-site driller): 1812

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 7, 1997