


OFFICE USE ONLY  
 Log No. 62865  
 Permit No. 222  
 Basin. 222



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. ....

PRINT OR TYPE ONLY

1. OWNER Bruce Jensen ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Post Office Box 9  
Mesquite, Nevada 89024

2. LOCATION NW 1/4 SE 1/4 Sec. 30 T. 13 S. R. 71 E. Clark County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	25	25
Sand		25	30	5
Gravel		30	35	5
Red sand		35	40	5
Gravel		40	55	15
Gravel some clay		55	60	5
Sand		60	70	10
Gravel, red clay, sand		70	90	20
Gravel & sand		90	100	10
Red clay, sand, some gravel		100	115	15
Red clay		115	130	15
Red clay & gravel		130	135	5
Red clay, sand, some gravel		135	145	10
Sandy gravel		145	170	25
Gravel & clay mixed		170	215	45
Sandy gravel		215	250	35
Gravel		250	300	50
Red sandy clay		300	320	20

8. WELL CONSTRUCTION

Diameter 9 7/8 inches Total depth 320 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness .188

Diameter	From	To
<u>6</u> inches	<u>+1</u> feet	<u>303</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 320 feet

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From 245 feet to 285 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
**APR 15 1988**  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started February 22, 19 88  
 Date completed March 3, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 153 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC.  
4185 West Harmon  
 Address Las Vegas, Nevada 89103  
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 4286A

Nevada contractor's driller's number issued by the Division of Water Resources 290

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489

Signed Richard R. Thompson  
 By driller performing actual drilling on site or contractor

Date April 13, 1988

