X X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62881
Permit No.
Basin 137A

NOTICE OF INTENT NO. 32846

1. OWNER Store Safe Redlands / R.C. Livestock
MAILING ADDRESS HCR 60 Box 62202
Round Mountain, Nv. 89045
ADDRESS AT WELL LOCATION No physical Adress
App. 6½ Mi. N.W. of Tonapah, Nv.

2. LOCATION NW ¼ NE ¼ Sec 24 T 4 N/S R 41 E Nye County
PERMIT NO. 50174 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This is an old Exploration hole drilled many years ago which had only 60' of 4" Csg. in the Top, Not cemented in. Owner pulled pump last Fall To be Replaced with a New pump, while pump was out of well, someone filled hole with Rocks and cans and owner could not install pump.				
We Rigged up over hole, pulled The existing 4" Csg. (60'), Tried To clean out well only To hit Metal obstruction At 123'. There was no ground water At This point. We pulled Tools out of hole. owner claimed original hole Tobe 200'				
We Poured into hole 15 sks Enviroplug (3/8 cut) and cemented Top 50' w/ Neat cement.				
Moved Rig 20' To Northwest To Re-drill well.				

Date started 1-23, 1996
Date completed 1-23, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Waytek Drilling Co. (Contractor)
Address 2220 Steve Dr. (Contractor)
Reno, Nv. 89511
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Leo Waytek (By driller performing actual drilling on site or contractor)
Date 1-27-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627