WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

CARD
~~PERMIT~~ # 0693

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 62945
Permit No.
Basin

1. OWNER GEORGE CRITES ADDRESS 4920 BILLMAN AVE. LAS VEGAS, NV. 89121

2. LOCATION NE ¼ NW ¼ Sec. 4 T. 20-S N/S R. 53 E. NYE County
PERMIT NO.

3. TYPE OF WORK
New Well XXX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable XX Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	6	6
SOFT BROWN CLAY		6	26	20
TOUGH BROWN CLAY		26	38	12
SOFT BROWN CLAY	X	38	114	76
BROWN CLAY	X	114	140	26

RECEIVED
JUL 23 1982
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started JULY 18, 19.82
Date completed JULY 19, 19.82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 3 feet 1/4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 140 feet
Casing record 8" CASING
Weight per foot 15# Thickness .156

Diameter	From	To
8" inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes XX No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes ☐ No XX
Gravel packed from feet to feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" W X 8" L
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 37 Feet below land surface 36
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES NYBERG
Address STAR ROUTE 5231, PAHRUMP, NEV. 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 7/20/82

USE ADDITIONAL SHEETS IF NECESSARY

O-627