DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 62952
Permit No.
Basin

1. OWNER Floyd, WAYNE ADDRESS P.O. Box 32 A PAHRUMP

2. LOCATION S-E ¼ S-E ¼ Sec. 4 T. 20 S N/S R. 53 E. Nye County
PERMIT NO. DOMESTIC

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	3'	3'
SAND CLAY STREAKS		3'	10'	7'
GRAVEL		10'	11'	1'
CALICHE		11'	16'	5'
SANDY CLAY		16	32'	16'
CALICHE		32	34'	2'
CLAY & SAND STREAKS	X	34	52'	18'
STICKY BROWN CLAY		52	63'	11'
CALICHE		63	68'	5'
CALICHE & CLAY STR.	X	68'	84'	16'
SANDY CLAY		84	96	12'
SAND STONE		96	99	3'
COARSE SAND	X	99	102	3'
WHITE CLAY		102	118'	16'
WHITE CLAY & SAND		118'	132'	14'
BENTONITE		132'	138'	6'
CLAY & SAND STONE		138'	142'	4'
SANDY CLAY		142'	173'	31'
SAND STONE		173'	174'	1'
SOFT WHITE CLAY		174	192'	18'
SAND & CLAY STR.		192	200	8'

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
NOV 27 1974
Div. of Water Resources
Main Office — Las Vegas, Nev.

BAILER TEST
G.P.M. 38 Draw down 0 feet 1 hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 200 feet
Casing record
Weight per foot 12.75 Thickness 10.846

Diameter	From	To
8 5/8" inches	0" feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 75 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 75' feet to 200 feet

Perforations:
Type perforation TORCH CUT
Size perforation ¼" x 12" 3 ROUNDS
From 170 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 37 Feet below land surface 37
Flow G.P.M.
Water temperature COLD° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE L. FLOYD
Address P.O. Box 32 A PAHRUMP
Nevada contractor's license number 12344
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 4-8-74

USE ADDITIONAL SHEETS IF NECESSARY

5471