WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 62979
Permit No.
Basin 104

NOTICE OF INTENT NO. 34497

1. OWNER J. & B ELDRIDGE
MAILING ADDRESS 288 E. WINNIE
CARSON CITY NV 89706
ADDRESS AT WELL LOCATION 4350 KINGS CANYON RD
CARSON CITY NV

2. LOCATION SE ¼ SE ¼ Sec. 14 T. 15 N/S R. 19 E. CARSON CITY County
PERMIT NO. (Issued by Water Resources) 07-061-69 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CONSTRUCTION FILL		0	4	4
CLAYEY LOAM, W AB BROKEN VOL		4	96	92
MOSTLY BRW CLAY SOME VOL COBBLES LARGE GRVL		96	200	104
CHANGING TO VOL, MINOR BRWN CLAY		104	315	211
TRANSITION TO a VOL TALUS TO SOLID VOL. HARD	X	315	395	80
SOLID, FRATURED VOL - V HARD	X	395	435	40

Date started 10/4, 1996
Date completed 10/24, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		3

8. WELL CONSTRUCTION
Depth Drilled 435 Feet Depth Cased 435 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	101 Feet
12¼ Inches		101 Feet	435 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	435

Perforations:
Type perforation SAWCUT
Size perforation 3X 3/32
From 275 feet to 295 feet
From 315 feet to 335 feet
From 355 feet to 375 feet
From ~~435~~ 415 feet to 435 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 PER TELCON
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 101 feet to 435 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CRK RD (Contractor)
CARSON CITY, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reisch (By driller performing actual drilling on site or contractor)
Date 11/4/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627