

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16566

1. OWNER Carson City School District ADDRESS AT WELL LOCATION 1111 N. Saliman Rd
 MAILING ADDRESS P.O. Box 603 CNS portion of Carson City School District Bldg
Carson City NV 89702 Yard on Robinson Street, East of Saliman Rd
 2. LOCATION SW 1/4 NW 1/4 Sec 16 T 15 N R 20 E Washoe County
 PERMIT NO. MO-1070 APN 10-041-53 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG (B2)

Material	Water Strata	From	To	Thickness
<u>silty sand</u>		<u>0'</u>	<u>1'</u>	<u>1'</u>
<u>clayey sand</u>		<u>1'</u>	<u>6'</u>	<u>4'</u>
<u>clayey silt</u>		<u>2'</u>	<u>6'</u>	
<u>silty sand</u>		<u>6'</u>	<u>11'</u>	<u>5'</u>
<u>clayey sand</u>		<u>11'</u>	<u>15'</u>	<u>4'</u>
<u>water level</u>		<u>7'</u>	<u>15'</u>	<u>7'</u>

8. WELL CONSTRUCTION
 Depth Drilled 15' Feet Depth Cased 15' Feet

HOLE DIAMETER (BIT SIZE)
 From 8.5 Inches To 15' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.70</u>	<u>0.308</u>	<u>0</u>	<u>15</u>

Perforations:
 Type perforation slotted screened
 Size perforation 0.020 inch

From 5' feet to 15' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-3 (benzene) Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 3 feet to 15 feet

Date started 7/23, 1996
 Date completed 7/23, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 7' feet below land surface
 Artesian flow no G.P.M. N/A P.S.I.
 Water temperature warm °F Quality mucky

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DALE A. LEHMAN Contractor
 Address 520 Edison Way Reno NV 89502 Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976
 Signed Dale A. Lehman
 By driller performing actual drilling on site or contractor
 Date 7/29/96