WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63002
Permit No.
Basin 090

NOTICE OF INTENT NO. 28801

1. OWNER Texaco
MAILING ADDRESS 5330 Primrose
Fair Oaks, California

ADDRESS AT WELL LOCATION 899 Tahoe Boulevard
Incline Village, Nevada

2. LOCATION ¼ SW ¼ Sec. 15 T. 16 N/S R. 18 E County
PERMIT NO. M/O 1053 (Issued by Water Resources) | Parcel No. 132-24-4,10,11,23 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELLY SILTY MED-FINE SAND		0	15	
SILTY SANDY GRAVEL		15	37	
GRAVELLY SILTY SAND		37	56	
SILTY MED-FINE SAND		56	64	
SAND W/GRANITIC GRAVEL		64	71	
GRANITE BOULDERS/GRAVEL		71	109	
CLAYEY SILTY MED-FINE SAND		109	113	
WEATHERED GRAVEL AND SAND		113	120	
CLAYEY SILTY MED-FINE SAND		120	123	
SILTY MED-FINE SAND		123	129	
MED-FINE SAND		129	139	
MED-FINE SAND		139	141.5	

RECEIVED
96 OCT 14 PM 12:11
STATE ENGINEERS OFFICE

Date started 5/29, 19 96
Date completed 6/4, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 141.5 Feet Depth Cased 95 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 5/8 Inches	0 Feet	141.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	95

Perforations:
Type perforation Slot
Size perforation .020
From 65 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 60
Placement Method: [XX] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 60 feet to 95 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Western Strata Exploration, Inc. (Contractor)
Address P.O. Box 1664
West Sacramento, Ca 95691 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0034236A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1937
Signed (By driller performing actual drilling on site or contractor)
Date 8/1/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627