

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 20720

1. OWNER RUSSELL HENRY JR ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1100 Marietta Way 870 Buckeye  
Sparks, Nevada 89431 Virginia City, Nevada 89440  
 2. LOCATION SE 1/4 SE 1/4 Sec. 30 T 18N N/S R 21 E Storey County  
 PERMIT NO. 003-451-25 Virginia City Highlands  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Yellow clays		1	16	15
Brown clays		16	110	94
Yellow clays		110	183	73
Pinkish to red clay		183	211	28
Brown clay with streaks of volcanic rock		211	385	174
Gray clays		385	430	45
Gray volcanic rock		430	480	50
Gray soft clays		480	493	13
Gray volcanic rock some small fracture				
NO WATER		493	673	180
Gray volcanic, softer some clay streaks		673	815	142
Gray clay (soft)		815	855	40
Gray volcanic rock		855	933	78
Gray clays (sandy)		933	1090	157
Gray volcanic rock (soft)		1090	1121	31
Gray volcanic rock		1121	1143	22
Fracture, gray volcanic rock (NO WATER)		1143	1156	13
Gray volcanic rock		1156	1175	19
No water encountered				
Caving in				
Secure hole till further decide on abandonment or go deeper				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From _____ To _____		
_____ Inches _____ Feet _____ Feet		
_____ Inches _____ Feet _____ Feet		
_____ Inches _____ Feet _____ Feet		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-6-94, 19\_\_\_\_\_  
 Date completed 6-10-94, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			

9. WATER LEVEL

Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources (the on-site driller) 923

Signed [Signature] Driller performing actual drilling on site or contractor  
 Date December 5, 1996