

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 31990

1. OWNER Bill Rogers ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3300 GRAHAM AVE Silver Springs, NV 89429 3415 GRAHAM AVE Silver Springs, NV 89429  
 2. LOCATION SW 1/4 SE 1/4 Sec. 27 T. 18 N. R. 34 E. Lyon County  
 PERMIT NO. 018-354-10 Subdivision Name Prospect #1  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
Clay		1	4	3
Clay & Boulders		4	4	2
Cemented Gravel		6	12	6
Limestone		12	52	40
Clay		52	65	13
Clay & GRAVEL		65	80	15
Cemented GRAVEL		80	82	2
Clay & GRAVEL		82	84	2
Boulders		84	88	4
Clay & GRAVEL		88	90	2
Rock		90	120	30
Clay & GRAVEL		120	125	5
Clay		125	138	13
SAND & GRAVEL	X	138	172	34

8. WELL CONSTRUCTION  
 Depth Drilled 172 Feet Depth Cased 172 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 52 Feet  
6 Inches 0 Feet 172 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>13.77</u>	<u>.188</u>	<u>0</u>	<u>172</u>

Perforations:  
 Type perforation # Machine  
 Size perforation 7/8 x 3  
 From 15.2 feet to 172 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 52  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

Date started 10/23, 1996  
 Date completed 11/7, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>0</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon Cannon Contractor  
 Address 4555 Hwy 50 W Contractor  
Silver Springs, NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 23317  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1453  
 Signed Vernon Cannon  
 By driller performing actual drilling on site or contractor  
 Date 11/11/96