WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63033
Permit No.
Basin 1[illegible]

NOTICE OF INTENT NO. 26387

1. OWNER GUARD, LTD
MAILING ADDRESS POBOX 7798 RENO, NV 89510
ADDRESS AT WELL LOCATION 5430 ANITA AVE. SILVER SPRG, NV 89429

2. LOCATION SW ¼ NE ¼ Sec. 32 T. 18N N/S R. 24 E LYON County
PERMIT NO. (Issued by Water Resources) 18-452-13 (Parcel No.) LOT 21 HOLLYWOOD HILLS #1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND/CLAY W/COBBLES		0	24	24
DECOMPOSED GRANITE (DG)		24	300	276
DG W/GRAVEL ZONES	✓	300	360	60

Date started 3-8, 1995
Date completed 3-15, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	110		4 HRS.

8. WELL CONSTRUCTION
Depth Drilled 360' Feet Depth Cased 362' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0 Feet	360 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2'	360'

Perforations:
Type perforation MECHANICAL SLOT
Size perforation 3/32 x 1 1/2
From 300 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 360' feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow NONE G.P.M. — P.S.I.
Water temperature — °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P. WILLIAMS 702/358-8280
Address 2545 WESTVIEW BLVD. SPARKS, NV. 89434 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 14483
Nevada driller's license number issued by the Division of Water Resources, the on-site driller A74
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3/15/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627